

ADVANCE COPY ☐ ISSUED ☐ SLOTTED

BY: _____ AT: _____ Z

DISSEM BY: 43/50 PER _____ # _____

ACTION ☐ RID COPY

LOGS 4

#984

SECRET
(When Filled In)

REPRODUCTION OF THIS COPY PROHIBITED

INDEX: ☐ YES ☐ NO

CLASSIFY TO FILE NO. 217 AM '68

X-REF TO FILE NO. _____

FILE RID ☐ RET TO _____

1	6
2	7
3	8
4	9
5	10

DESTROY ☐ SIG.

INFO: _____

FILE. VR. COMM 7, DD 52, SECUR 4, PPB

SECRET 250220Z JUL 69 CITE 0984

25X1A

25 JUL 69 IN 09519

19

25X1A

25X1A

POWER HOUSE AND AIR CONDITIONING PROGRESS REPORT

NO. 11

1. NO MEASURABLE PROGRESS SINCE LAST REPORT - STILL 73 PER CENT COMPLETE.

2. CLEAN-UP WORK IN POWER HOUSE NOT YET FINISHED.

CABLES TIEING TWO 235KW GM'S TO SWITCHGEAR STILL TO BE PROPERLY TERMINATED AT GENERATOR END, AND CONSIDERABLE PAINTING AND PATCHING REMAINS TO BE DONE.

3. NEW CHILLER UNITS FOR AIR CONDITIONING PLANT NOW ON SITE AND SHOP DRAWINGS OF REVISED ASSEMBLY NOW IN HANDS OF

SECRET

52 JUL 10 14

REC'D

C
DC PT-25
EX 11-7-25
SAC
SA
C/RE
RO
C/En
PE
APPR
COMM
CONC
INFO
PREP
RETU
FILE

25X1A

SECRET